



Date: Monday, November 3, 2025

Town of Deep River

100 Deep River Road, P.O Box 400, Deep River, ON K0J 1P0

www.deepriver.ca

Addendum #1

**Bid Opportunity: 2025-RFT-001 Deep River Water
Treatment Plant Upgrades**

**Closing Date: Wednesday, November 19, 2025 by 13:30:00
EST**

This Addendum will form part of the RFT document.

In the event of any conflicting or inconsistent information, this addendum will take precedence over all requirements of the original RFT document, and any addenda issued previously.

All other requirements of the RFT document remain the same.

Bidders must acknowledge receipt of this addendum, in the field requested, when submitting their bid.

PART 1 – BIDDER’S QUESTIONS:

1.1 Question 1: I kindly request you to consider the Golden Anderson (GA) for the supply of Valves as below.,

- 2.13 Butterfly Valves - Please include GA Series 800 AWWA Butterfly Valve as equivalent.

- 2.14 Silent Globe Check Valve - Please include GA Fig F280 (Globe Style) or F290 (Wafer Style) as equivalent.

Enclosing the product datasheets for your reference, the proposed valves will meet the project requirement.

If named, we will be able to bring value and competition to the bidding process.

Please let me know if you require additional information for your evaluation, I'll be happy to furnish them.

Answer: GA BFV and Silent Globe Check Valve proposed are acceptable alternatives for valves to be supplied as part of contractor's base scope.

End of Addendum.